



# DECLARATION

## Test Certificate

Date issued 28-06-2022 Report number 4405-1  
 Certificate number ErP/ELEC/0558/22/005 Original/Amendment Original

## EC Ecodesign Certificate

Issued by Kiwa Ltd

Circulating Pump Model Name	Energy Efficiency Index, $\epsilon_{EEI}$	Test Report
Tucson RS25/6EAQ130SS	0.20	4405-1

### Manufacturer's Name and Address:

Tucson Pumps Ltd  
 Instantor Works  
 Santry Avenue  
 Dublin D09 K160  
 Ireland

### Declaration

Kiwa Limited declares that Energy Efficiency Index test results for the products listed above have been obtained in accordance with the requirements of the Energy Using Products Directive according to Commission Regulation (EC) No 641/2009 (Directive 2005/32/EC) using the relevant methods of measurement and calculation of energy efficiency index for glandless circulators as detailed in 2013/C 254/04 of the Official Journal of the European Union (OJEC) C254 dated 4 September 2013.

Signed on behalf of Kiwa Limited

Mr I R Summerfield – Head of Special Projects

390170301